

VOC Content Test Certificate

Wednesday 23rd November 2022

Supplier: Selleys Pty Ltd (1 Gow Street, PADSTOW, NSW, 2211, Australia).

Sample Description: PROSERIES FLEXISEAL SEALANT

Date Tested: November 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 & ASTM D2369 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

<p align="center">Specification</p> <p align="center">Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B</p>	<p align="center">PROSERIES FLEXISEAL SEALANT</p>
<p align="center">Acoustic Sealants, Architectural Sealants Limit: 250 grams per litre</p>	<p align="center">93 grams per Litre as VOC content per material</p>
<p align="center">Meets GBCA VOC Content Requirement</p>	<p align="center">Yes</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

Issued date: 23/11/2022

Expiry date: 23/11/2027

P22100110