

VOC Content Test Certificate

Monday 18th December 2023

Supplier: Selleys Pty Ltd (1 Gow Street, PADSTOW, NSW 2211, AUSTRALIA).
Product Name: Selleys AQUADHERE Interior Wood Glue
Date Tested: 18th December 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)
Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Selleys AQUADHERE Interior Wood Glue
General Purpose Adhesives and Sealants: 50 grams per litre	2 grams per litre as VOC content per material
<i>We hereby certify Selleys AQUADHERE Interior Wood Glue is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant

Travis Hale
BSc (Biotechnology)
Senior Consultant